

LED OUTLINE LIGHT



Light Output Ratio:	100.0%
Luminaire Power:	0 W
90% Beam Spread	59.2V x 66.4H
50% Beam Lumens	748.5 lumens per klm.

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature: 23DEG
Operators:
Test Date: 2018-08-02

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.402
Humidity: 56%
Test Distance: 10.580m [K=1.0000]
Remarks:

Floodlight Summary:

Report based on lamp delivering 1000 lumens.

Maximum Intensity	250.9 cd per klm.
(Luminaire orientation as tested.)	0.0 degrees vertical
	0.0 degrees horizontal

Beam Spread	At 10% of Imax	187.6V x 180.0H
	At 50% of Imax	135.9V x 137.3H
	At 90% of Imax	59.2V x 66.4H

Beam Flux	Total	1000.0 lumens per klm.
	To 10% of Imax	961.0 lumens per klm.
	To 50% of Imax	748.5 lumens per klm.
	To 90% of Imax	224.7 lumens per klm.

Upward LOR	5.1 %
Downward LOR	94.9 %


Luminaire Efficiency(Light Output Ratio)	100.0 %
--	---------

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature:23DEG
Operators:
Test Date:2018-08-02

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.402
Humidity:56%
Test Distance:10.580m [K=1.0000]
Remarks:

LUMINAIRE PHOTOMETRIC TEST REPORT

Test:U:24.232V I:0A P:0W PF:0.0000 Freq:0Hz Lamp Flux:158.546x1 lm		
NAME: TL-OU-3110B-3 6W RGB 136D	TYPE:	SERIAL No.:
	SUR.:	



DATA OF LAMP		PHOTOMETRIC DATA	
MODEL		Imax(cd)	39.78
NOMINAL POWER(W)	6	AVAILABILITY(%)	96.1
RATED VOLTAGE(V)	24	Avai. FLUX(lm)	152.3
NOMINAL FLUX(lm)	158.546	LOR(%)	100.0
LAMPS INSIDE	1	TOTAL FLUX(lm)	158.5
TEST VOLTAGE(V)	24.1376	q @50%(H,V)	137,136DEG

		AREA FLUX DIAGRAM																UNIT:lm		F t	F a
		0.02	0.07	0.12	0.17	0.21	0.26	0.29	0.33	0.35	0.35	0.33	0.29	0.25	0.19	0.15	0.11	0.06	0.02	3.57	3.57
VERTICAL(DEG)	90	0.02	0.08	0.15	0.23	0.31	0.39	0.46	0.50	0.52	0.52	0.50	0.45	0.37	0.29	0.21	0.14	0.08	0.02	5.24	5.24
	80	0.03	0.09	0.18	0.28	0.40	0.50	0.58	0.64	0.67	0.67	0.64	0.57	0.48	0.38	0.27	0.17	0.09	0.02	6.65	6.65
	70	0.03	0.10	0.21	0.33	0.47	0.59	0.70	0.78	0.83	0.83	0.78	0.69	0.58	0.45	0.32	0.19	0.10	0.03	8.01	8.01
	60	0.03	0.11	0.23	0.38	0.53	0.68	0.82	0.92	0.98	0.98	0.92	0.81	0.67	0.52	0.36	0.22	0.10	0.03	9.28	9.28
	50	0.03	0.12	0.25	0.41	0.59	0.76	0.92	1.03	1.09	1.09	1.03	0.90	0.75	0.57	0.40	0.24	0.11	0.03	10.3	10.3
	40	0.03	0.13	0.27	0.44	0.64	0.82	0.99	1.10	1.16	1.16	1.09	0.97	0.80	0.61	0.42	0.25	0.12	0.03	11.0	11.0
	30	0.03	0.13	0.28	0.46	0.67	0.86	1.02	1.13	1.18	1.18	1.11	1.00	0.83	0.64	0.44	0.27	0.12	0.03	11.4	11.4
		0.03	0.13	0.28	0.47	0.68	0.88	1.04	1.14	1.19	1.17	1.12	1.01	0.85	0.66	0.46	0.28	0.13	0.03	11.6	11.6
		0.03	0.13	0.28	0.46	0.66	0.85	1.00	1.10	1.15	1.17	1.13	1.02	0.87	0.67	0.47	0.28	0.13	0.03	11.4	11.4
		0.03	0.13	0.27	0.44	0.63	0.81	0.96	1.06	1.12	1.13	1.08	0.98	0.83	0.65	0.45	0.27	0.13	0.03	11.0	11.0
	-30	0.03	0.12	0.26	0.42	0.59	0.76	0.91	1.01	1.06	1.07	1.02	0.93	0.78	0.61	0.43	0.26	0.12	0.03	10.4	10.4
	-40	0.03	0.12	0.24	0.39	0.55	0.70	0.84	0.93	0.99	0.99	0.94	0.85	0.72	0.56	0.40	0.24	0.11	0.03	9.63	9.63
	-50	0.03	0.11	0.22	0.35	0.49	0.63	0.75	0.83	0.88	0.88	0.84	0.76	0.64	0.51	0.36	0.22	0.11	0.03	8.63	8.63
	-60	0.03	0.10	0.20	0.31	0.43	0.55	0.64	0.72	0.75	0.76	0.72	0.65	0.56	0.44	0.32	0.20	0.10	0.03	7.49	7.49
	-70	0.02	0.09	0.17	0.27	0.37	0.46	0.54	0.59	0.62	0.62	0.60	0.54	0.47	0.37	0.27	0.17	0.09	0.02	6.27	6.27
	-80	0.02	0.08	0.14	0.22	0.29	0.36	0.43	0.47	0.49	0.49	0.47	0.43	0.37	0.29	0.21	0.14	0.08	0.02	5.00	5.00
-90	0.02	0.07	0.11	0.16	0.21	0.25	0.29	0.32	0.35	0.35	0.33	0.29	0.25	0.21	0.16	0.11	0.07	0.02	3.54	3.54	
		-90	-80	-70	-60	-50	-40	-30	-20	HORIZONTAL(DEG)			20	30	40	50	60	70	80	90	
F t	0.49	1.90	3.86	6.20	8.71	11.1	13.2	14.6	15.4	15.4	14.6	13.1	11.1	8.62	6.10	3.76	1.83	0.48	150	---	
F a	0.49	1.90	3.86	6.20	8.71	11.1	13.2	14.6	15.4	15.4	14.6	13.1	11.1	8.62	6.10	3.76	1.83	0.48	---	150	

one-half-peak spread: U:65.5,D:56.8 , L:68.4,R:64.6


NEMA Beam Type: Type 7

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature:23DEG
Operators:
Test Date:2018-08-02

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.402
Humidity:56%
Test Distance:10.580m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

Test:U:24.232V I:0A P:0W PF:0.0000 Freq:0Hz Lamp Flux:158.546x1 lm		
NAME: TL-OU-3110B-3 6W RGB 136D	TYPE:	SERIAL No.:
	SUR.:	




C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature:23DEG
Operators:
Test Date:2018-08-02

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.402
Humidity:56%
Test Distance:10.580m [K=1.0000]
Remarks:

ISOLUX DIAGRAM


Test:U:24.232V I:0A P:0W PF:0.0000 Freq:0Hz Lamp Flux:158.546x1 lm		
NAME: TL-OU-3110B-3 6W RGB 136D	TYPE:	SERIAL No.:
	SUR.:	



C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature: 23DEG
Operators:
Test Date: 2018-08-02

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.402
Humidity: 56%
Test Distance: 10.580m [K=1.0000]
Remarks:

Planar Illuminance Curve




C Range: 0 - 360DEG
 C Interval: 10.0DEG
 Test Speed: HIGH
 Temperature: 23DEG
 Operators:
 Test Date: 2018-08-02

g Range: 0 - 180DEG
 g Interval: 1.0DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.402
 Humidity: 56%
 Test Distance: 10.580m [K=1.0000]
 Remarks:

AAI Figure

Test:U:24.232V I:0A P:0W PF:0.0000 Freq:0Hz Lamp Flux:158.546x1 lm		
NAME: TL-OU-3110B-3 6W RGB 136D	TYPE:	SERIAL No.:
	SUR.:	

Flux out:117.6 lm



Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature:23DEG
Operators:
Test Date:2018-08-02

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.402
Humidity:56%
Test Distance:10.580m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:24.232V I:0A P:0W PF:0.0000 Freq:0Hz Lamp Flux:158.546x1 lm		
NAME: TL-OU-3110B-3 6W RGB 136D	TYPE:	SERIAL No.:
	SUR.:	

Table--1																	UNIT: cd		
H(DEC)	-90	-85	-80	-75	-70	-65	-60	-55	-50	-45	-40	-35	-30	-25	-20	-15	-10	-5	0
V(DEC)	-180	7.52	2.82	1.71	1.10	1.37	0.78	0.57	0.61	0.65	0.67	0.70	0.72	0.75	0.76	0.79	0.80	0.82	0.83
	-170	7.52	2.89	1.89	0.99	1.38	0.79	0.55	0.58	0.62	0.65	0.67	0.69	0.71	0.75	0.77	0.80	0.81	0.82
	-160	7.52	3.04	2.13	0.80	1.48	0.87	0.55	0.57	0.59	0.62	0.64	0.68	0.70	0.72	0.75	0.76	0.77	0.79
	-150	7.52	3.24	2.32	1.03	1.48	1.05	0.63	0.54	0.58	0.60	0.63	0.66	0.69	0.69	0.70	0.71	0.73	0.75
	-140	7.52	3.52	2.38	1.91	1.09	1.35	0.83	0.56	0.55	0.57	0.61	0.63	0.67	0.70	0.71	0.72	0.70	0.70
	-130	7.52	3.97	2.70	2.56	1.11	1.32	1.23	0.77	0.54	0.54	0.55	0.57	0.57	0.59	0.60	0.62	0.63	0.64
	-120	7.52	4.66	3.23	2.61	2.50	1.15	1.17	1.35	0.89	0.59	0.55	0.60	0.74	1.29	1.63	1.96	2.08	2.14
	-110	7.52	5.57	3.98	3.29	2.76	2.75	2.18	1.06	1.08	1.23	0.82	0.60	0.56	0.73	1.02	1.60	2.27	2.97
	-100	7.52	6.59	5.69	4.66	3.91	3.49	3.17	2.34	1.74	1.53	1.09	1.11	1.18	0.87	0.64	0.72	0.87	1.57
	-90	7.52	7.51	7.50	7.45	7.40	7.40	7.40	7.27	7.14	7.26	7.37	7.28	7.18	7.15	7.12	7.22	7.32	8.03
	-80	7.52	8.22	8.56	9.03	9.54	10.0	10.4	10.8	11.2	11.6	12.0	12.5	12.8	13.3	13.7	13.8	13.9	14.0
	-70	7.52	8.73	9.60	10.5	11.3	12.1	13.0	13.8	14.6	15.3	16.1	16.7	17.2	17.5	17.8	18.0	18.2	18.3
	-60	7.52	9.20	10.5	11.7	13.0	14.2	15.4	16.6	17.6	18.6	19.5	20.3	20.9	21.4	21.9	22.3	22.5	22.7
	-50	7.52	9.65	11.3	12.9	14.5	16.1	17.6	19.1	20.4	21.6	22.7	23.7	24.5	25.2	25.9	26.4	26.8	27.1
	-40	7.52	10.1	12.0	13.9	15.9	17.8	19.6	21.3	22.9	24.3	25.6	26.8	27.9	28.8	29.5	30.2	30.7	31.0
	-30	7.52	10.4	12.6	14.9	17.0	19.1	21.2	23.1	24.9	26.6	28.2	29.5	30.7	31.7	32.5	33.2	33.7	34.0
	-20	7.52	10.6	13.1	15.6	18.0	20.3	22.5	24.6	26.6	28.5	30.2	31.7	32.9	33.9	34.7	35.3	35.8	36.1
	-10	7.52	10.8	13.5	16.2	18.9	21.4	23.7	25.9	28.0	29.8	31.6	33.1	34.3	35.3	36.1	36.7	37.1	37.4
	0	7.52	10.9	13.7	16.5	19.4	22.1	24.6	27.1	29.5	31.7	33.7	35.3	36.7	37.7	38.5	39.1	39.5	39.7
	10	7.52	10.8	13.6	16.4	19.2	21.8	24.4	26.8	29.1	31.3	33.3	35.1	36.5	37.6	38.3	38.8	39.1	39.2
	20	7.52	10.7	13.3	16.0	18.6	21.2	23.6	25.9	28.2	30.4	32.3	34.0	35.5	36.7	37.6	38.3	38.7	38.8
	30	7.52	10.5	12.9	15.4	17.8	20.2	22.4	24.6	26.6	28.5	30.4	32.0	33.5	34.8	35.9	36.7	37.2	37.5
	40	7.52	10.2	12.3	14.5	16.7	18.8	20.9	22.7	24.4	26.1	27.7	29.1	30.5	31.7	32.8	33.5	34.1	34.5
	50	7.52	9.75	11.6	13.5	15.3	17.1	18.9	20.4	21.9	23.2	24.5	25.6	26.7	27.7	28.5	29.1	29.6	29.9
	60	7.52	9.32	10.8	12.2	13.8	15.2	16.5	17.7	19.0	20.1	21.1	21.9	22.6	23.2	23.7	24.2	24.5	24.7
	70	7.52	8.87	9.85	10.9	11.9	12.9	13.9	14.8	15.7	16.5	17.3	18.0	18.5	18.9	19.1	19.3	19.5	19.6
	80	7.52	8.34	8.86	9.39	9.98	10.5	10.9	11.4	11.9	12.3	12.7	13.2	13.6	14.0	14.4	14.6	14.7	14.7
	90	7.52	7.49	7.47	7.53	7.60	7.53	7.46	7.35	7.24	7.11	6.98	6.99	7.01	6.87	6.74	6.84	6.94	7.46
	100	7.52	6.46	5.37	4.42	3.83	3.49	3.15	2.36	1.63	1.07	0.52	0.57	0.63	0.55	0.47	0.59	0.74	1.08
	110	7.52	5.42	3.81	3.35	2.96	2.91	2.03	1.24	1.33	0.91	0.68	0.60	0.75	0.98	1.53	2.17	2.79	3.39
	120	7.52	4.53	3.28	2.83	2.49	1.12	1.38	1.42	0.95	0.64	0.59	0.63	0.77	0.98	1.28	1.60	1.93	2.07
	130	7.52	3.88	2.73	2.65	1.06	1.52	1.29	0.81	0.57	0.54	0.56	0.59	0.60	0.60	0.60	0.59	0.60	0.61
	140	7.52	3.51	2.51	1.79	1.26	1.40	0.89	0.59	0.56	0.58	0.62	0.63	0.69	0.72	0.74	0.70	0.67	0.68
	150	7.52	3.24	2.43	0.92	1.56	1.06	0.65	0.57	0.59	0.61	0.63	0.65	0.66	0.69	0.72	0.72	0.70	0.71
	160	7.52	3.04	2.18	0.85	1.50	0.87	0.55	0.56	0.60	0.63	0.67	0.68	0.68	0.71	0.73	0.76	0.77	0.77
	170	7.52	2.90	1.90	1.03	1.39	0.79	0.55	0.57	0.60	0.62	0.65	0.68	0.71	0.75	0.77	0.79	0.81	0.82
	180	7.52	2.82	1.71	1.10	1.37	0.78	0.57	0.61	0.65	0.67	0.70	0.72	0.75	0.76	0.79	0.80	0.82	0.83

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature:23DEG
Operators:
Test Date:2018-08-02

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.402
Humidity:56%
Test Distance:10.580m [K=1.0000]
Remarks:

LUMINOUS DISTRIBUTION INTENSITY DATA

Test:U:24.232V I:0A P:0W PF:0.0000 Freq:0Hz Lamp Flux:158.546x1 lm		
NAME: TL-OU-3110B-3 6W RGB 136D	TYPE:	SERIAL No.:
	SUR.:	

Table--2

UNIT: cd

H(DEC) V(DEC)	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	
-180	0.81	0.80	0.78	0.75	0.74	0.71	0.69	0.67	0.63	0.60	0.57	0.54	0.66	1.22	0.88	1.76	3.02	7.82	
-170	0.82	0.80	0.77	0.75	0.73	0.71	0.67	0.65	0.62	0.59	0.55	0.53	0.66	1.24	0.83	1.93	3.11	7.82	
-160	0.78	0.76	0.75	0.73	0.70	0.68	0.65	0.64	0.62	0.58	0.54	0.50	0.73	1.34	0.67	2.13	3.26	7.82	
-150	0.74	0.72	0.71	0.70	0.68	0.66	0.63	0.61	0.58	0.57	0.54	0.56	0.91	1.38	1.06	2.27	3.48	7.82	
-140	0.70	0.69	0.71	0.71	0.70	0.66	0.61	0.58	0.56	0.54	0.54	0.74	1.22	1.04	2.04	2.33	3.79	7.82	
-130	0.63	0.62	0.61	0.59	0.58	0.57	0.57	0.54	0.52	0.51	0.68	1.12	1.30	1.09	2.68	2.77	4.31	7.82	
-120	2.11	2.01	1.68	1.33	1.00	0.77	0.61	0.54	0.55	0.80	1.25	1.16	1.13	2.62	2.60	3.52	5.06	7.82	
-110	3.03	2.38	1.70	1.09	0.77	0.57	0.61	0.82	1.21	1.04	1.02	2.23	2.74	2.74	3.56	4.28	6.00	7.82	
-100	1.60	0.92	0.73	0.60	0.88	1.24	1.22	1.29	1.50	1.48	2.26	3.43	3.73	4.17	4.99	6.11	7.06	7.82	
-90	8.16	7.59	7.42	7.25	7.27	7.28	7.45	7.62	7.48	7.34	7.52	7.69	7.76	7.83	7.89	7.95	7.88	7.82	
-80	14.0	14.0	13.9	13.7	13.3	12.9	12.4	11.9	11.5	11.1	10.7	10.4	10.1	9.60	9.00	8.46	8.11	7.82	
-70	18.3	18.3	18.2	18.0	17.7	17.3	16.8	16.2	15.3	14.5	13.7	12.9	12.1	11.3	10.6	9.69	8.50	7.82	
-60	22.8	22.7	22.5	22.1	21.7	21.2	20.6	19.8	18.8	17.8	16.7	15.4	14.2	12.9	11.7	10.6	9.01	7.82	
-50	27.2	27.0	26.7	26.2	25.6	24.9	24.1	23.1	22.0	20.8	19.4	17.8	16.1	14.5	12.8	11.3	9.56	7.82	
-40	31.1	30.9	30.5	30.0	29.3	28.4	27.3	26.2	24.9	23.4	21.7	19.9	17.9	15.9	13.9	11.8	10.1	7.82	
-30	34.1	34.0	33.6	33.1	32.3	31.3	30.2	28.8	27.3	25.6	23.7	21.6	19.4	17.1	14.7	12.4	10.4	7.82	
-20	36.3	36.2	35.9	35.4	34.7	33.7	32.5	31.0	29.3	27.4	25.3	23.0	20.6	18.0	15.4	12.8	10.6	7.82	
-10	37.9	37.9	37.7	37.2	36.5	35.5	34.2	32.6	30.7	28.6	26.4	24.0	21.3	18.6	15.8	13.1	10.7	7.82	
0	39.7	39.5	39.2	38.6	37.7	36.6	35.2	33.5	31.5	29.3	27.0	24.5	21.7	18.9	16.0	13.2	10.8	7.82	
10	38.8	38.4	38.0	37.3	36.4	35.2	33.7	32.0	30.0	28.1	25.9	23.6	21.1	18.4	15.7	13.0	10.7	7.82	
20	38.7	38.3	37.7	36.9	35.9	34.5	33.0	31.2	29.2	27.1	24.8	22.4	20.0	17.6	15.1	12.7	10.6	7.82	
30	37.4	37.0	36.3	35.4	34.2	32.8	31.2	29.5	27.6	25.6	23.6	21.3	19.0	16.6	14.4	12.2	10.4	7.82	
40	34.4	34.0	33.3	32.4	31.3	29.9	28.5	27.0	25.3	23.6	21.7	19.7	17.6	15.5	13.5	11.6	10.0	7.82	
50	29.8	29.5	28.9	28.2	27.3	26.3	25.2	24.0	22.6	21.0	19.4	17.7	16.0	14.2	12.5	11.0	9.38	7.82	
60	24.7	24.5	24.1	23.6	23.0	22.3	21.4	20.4	19.3	18.0	16.7	15.4	14.1	12.7	11.4	10.4	8.84	7.82	
70	19.6	19.5	19.3	19.0	18.6	18.1	17.3	16.5	15.6	14.7	13.8	12.9	11.9	11.1	10.4	9.29	8.37	7.82	
80	14.7	14.7	14.4	14.1	13.6	13.0	12.5	11.9	11.5	11.1	10.7	10.5	10.1	9.46	8.69	8.18	7.98	7.82	
90	7.50	7.02	6.96	6.89	7.02	7.14	6.97	6.80	5.99	5.18	6.45	7.71	7.75	7.78	7.70	7.63	7.72	7.82	
100	1.06	0.70	0.58	0.49	0.58	0.66	0.60	0.58	1.17	1.75	2.37	3.35	3.74	4.11	4.72	5.64	6.80	7.82	
110	2.73	2.07	1.45	0.93	0.71	0.58	0.63	0.85	1.26	1.17	1.05	2.18	2.76	2.72	3.46	4.02	5.78	7.82	
120	2.07	1.92	1.58	1.25	0.95	0.75	0.62	0.58	0.62	0.88	1.32	1.24	1.14	2.56	2.55	3.39	4.88	7.82	
130	0.64	0.63	0.61	0.61	0.61	0.61	0.60	0.58	0.56	0.56	0.75	1.16	1.37	1.08	2.59	2.59	4.19	7.82	
140	0.70	0.71	0.73	0.73	0.70	0.68	0.65	0.64	0.61	0.59	0.59	0.78	1.25	1.16	1.90	2.27	3.74	7.82	
150	0.74	0.72	0.71	0.71	0.69	0.68	0.68	0.66	0.64	0.61	0.59	0.61	0.95	1.44	1.03	2.23	3.44	7.82	
160	0.78	0.77	0.77	0.75	0.73	0.71	0.70	0.68	0.66	0.63	0.60	0.57	0.79	1.36	0.73	2.09	3.24	7.82	
170	0.81	0.80	0.80	0.78	0.77	0.73	0.70	0.69	0.66	0.64	0.60	0.57	0.70	1.25	0.87	1.91	3.09	7.82	
180	0.81	0.80	0.78	0.75	0.74	0.71	0.69	0.67	0.63	0.60	0.57	0.54	0.66	1.22	0.88	1.76	3.02	7.82	

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: HIGH
Temperature:23DEG
Operators:
Test Date:2018-08-02

g Range: 0 - 180DEG
g Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.402
Humidity:56%
Test Distance:10.580m [K=1.0000]
Remarks: